



NOTES

1. DEPTH OF WATERMAIN & SEWERS AS PER TOWN STANDARD DESIGN CRITERIA.
2. WHEN POWER AND COMMUNICATION DUCTS AND CABLES ENCOUNTER HYDRANTS AND VALVES, THE CABLE IS TO LOOP BEHIND THE HYDRANT AWAY FROM THE WATERMAIN.
3. PAVEMENT STRUCTURE TO BE INSTALLED IN ACCORDANCE WITH THE TOWN'S PAVEMENT DESIGN CRITERIA. THE FOLLOWING IS A MINIMUM PAVEMENT STRUCTURE AND MAY BE GREATER IN ACCORDANCE WITH GEOTECHNICAL REPORT:
 40mm SURFACE COURSE ASPHALT.
 60mm BASE COURSE ASPHALT.
 150mm GRANULAR "A".
 400mm GRANULAR "B".
4. THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL & NURSERY SOD.
5. TREES TO BE PLACED IN LOCATIONS APPROVED BY THE TOWN.
6. LOCALIZED GRADING AROUND TRANSFORMER TO MAINTAIN A LEVEL TRANSFORMER PLATFORM
7. TELECOMMUNICATIONS PEDESTALS ARE TO BE LOCATED ON THE NON-OPENING SIDE OF A TRANSFORMER OR SWITCH GEAR.
8. ALL SIDEWALK IS TO BE CONSTRUCTED ON A PROPERLY COMPACTED FOUNDATION OF A MINIMUM OF 150mm OF GRANULAR 'A'.
9. DESIGNER TO CONTACT TOWN BEFORE INITIATING DESIGN OF UTILITIES TO CONFIRM USE OF I.T. DUCTS WITHIN THE JOINT USE UTILITY TRENCH.



**URBAN LOCAL ROAD
20.0m ROAD ALLOWANCE
8.5m PAVEMENT WIDTH**

DRAWN: _____ APR'D: _____
 SCALE: N.T.S. DATE: JUNE 2011

4.	REVISED NOTES	TOI	SEPT 2025
3.	REVISED NOTES	TOI	MAY 2019
2.	REVISED NOTES	TOI	APRIL 2018
1.	REVISED NOTES AND WATER SERVICES	TOI	APRIL 2015
NO.	REVISIONS	APR'D	DATE

METRIC
 ALL DIMENSIONS IN mm
 UNLESS OTHERWISE NOTED

**TOISD
201**