



NOTES:

1. DEPTH OF WATERMAIN & SEWERS AS PER TOWN STANDARD DESIGN CRITERIA.
2. WHEN POWER AND COMMUNICATION DUCTS AND CABLES ENCOUNTER HYDRANTS AND VALVES, THE CABLE IS TO LOOP BEHIND THE HYDRANT AWAY FROM THE WATERMAIN.
3. PAVEMENT STRUCTURE TO BE INSTALLED IN ACCORDANCE WITH THE TOWN'S PAVEMENT DESIGN CRITERIA. THE FOLLOWING IS A MINIMUM PAVEMENT STRUCTURE & MAY BE GREATER IN ACCORDANCE WITH GEOTECHNICAL REPORT:
 40mm SURFACE COURSE ASPHALT.
 60mm BASE COURSE ASPHALT.
 150mm GRANULAR "A".
 400mm GRANULAR "B".
4. THE BOULEVARDS REQUIRE A MINIMUM OF 300mm OF TOPSOIL & NURSERY SOD.
5. TREES TO BE PLACED IN LOCATION APPROVED BY THE TOWN.
6. IF A JOINT USE UTILITY TRENCH IS TO BE USED THEN POSITION NO. 1 IS TO BE USED FOR GAS MAIN INSTALLATION.
7. IF A JOINT USE UTILITY TRENCH IS NOT AVAILABLE THEN POSITION NO. 2 IS TO BE USED FOR GAS MAIN INSTALLATION.
8. TELECOMMUNICATIONS PEDESTALS ARE TO BE LOCATED ON THE NON-OPENING SIDE OF A TRANSFORMER OR SWITCH GEAR.
9. ALL SIDEWALK IS TO BE CONSTRUCTED ON A PROPERLY COMPACTED FOUNDATION OF A MINIMUM OF 150mm OF GRANULAR 'A'.
10. DESIGNER TO CONTACT TOWN BEFORE INITIATING DESIGN OF UTILITIES TO CONFIRM USE OF I.T. DUCTS WITHIN THE JOINT USE UTILITY TRENCH.



**WINDOW STREET
20.0m ROAD ALLOWANCE
8.5m PAVEMENT WIDTH**

DRAWN:	APR'D:	NO.	REVISIONS	APR'D	DATE
SCALE: N.T.S.	DATE: JUNE 2011	1.	REVISED NOTES AND WATER SERVICES	TOI	APRIL 2015
		2.	TO REFLECT TOWN STANDARDS	TOI	APRIL 2018
		3.	TO REFLECT TOWN STANDARDS	TOI	MAY 2019
		4.	REVISED NOTES	TOI	SEPT 2025

METRIC
ALL DIMENSIONS IN mm
UNLESS OTHERWISE NOTED

**TOISD
202**